



BESCOM

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

NO: CEE/BMAZ/SE(O)/AEE-2/F- 249/

Encl:

2561-64

Office Of

The Chief Engineer Ele.,
[C,O&M], BMAZ, No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan,
Nrupathunga Road, Bangalore-560 001.

Date:

6/6/09

To,

M/s. Purvankara Constructions,
No. 130/1, Ulsoor Road,
Bangalore.

Sir,

- Sub:** Issue of NOC for arranging power supply to an extent of 16MW in favour of Purvankara Constructions Sy. No. 30, 31, 32, 34 & 161, Kadathanamale Village, Doddaballapura Road, Bangalore.
- Reg:**
1. SEE(CO&M)/BCN/EEE(O)/AEE-2/7405-07 dt: 18.09.08 of Superintending Engineer (El.) Bangalore North Circle.
 2. T. O. Ltr. No. CEE/BMAZ/EEE(O)/AEE-1/F-249/11985-87 dt: 16.12.08.
 3. No. CEE(P&C)/KCO-95/8971/2008-09 dt: 06.05.09 45th TCCM Proceedings dt: 30.03.09 subject No. 22
 4. No. BESCOM/BC-47/GM(EL.)/PP/F-3221(47)/08-09/451 dt: 01.06.2009.

With reference to the above, **'No Objection Certificate'** from **BMAZ, BESCOM for the requisition load of 16 MW** is hereby issued for the proposed Residential Apartments in favour of M/s. Purvankara Constructions, at Sy. No. 30, 31, 32, 34 & 161 Kadathanamale Village, Doddaballapura Road, Bangalore at C-7 Sub-Division, Addl. Central Division, subject to following conditions:-

1. M/s. Purvankara Constructions have to establish a new 66/11 KV consumer sub-station of 2x20 MVA capacity at the above premises by constructing 66 KV double circuit line with coyote ACSR on DC towers from 220/66 KV Doddaballapura Sub-station to the proposed consumer station for a distance of 8 Kms besides constructing additional 66 KV bay, duly providing **66 KV breakers, CT's Control Panel, Control Wiring, GOS etc under self execution.**

2. Alternate power supply shall be arranged by the consumer by executing the following works under self execution:
 - a. Construction of LILO line from the existing 66 KV DG Plant-DB Pura-2 line to the proposed consumer sub-station using Coyote ACSR conductor on DC towers.
 - b. Replacement of existing copper conductor 1/0 of DC lines from DG plant to the proposed tapping point i.e. from LOC1 to LOC41 by coyote ACSR conductor.
 - c. The released copper conductor should be credited to the BESCO stores.
3. All the above works shall be carried out through the Government Class-1 Electrical contractor under the guidance of the KPTCL.
4. Execution of works mentioned above has to be executed from your end at your cost under self-execution on payment of 10% supervision charges on estimate cost.
5. Payment of augmentation charges for availing HT power supply on 11 KV and observance of other formalities mentioned in conditions of supply of Electricity of Distribution License.
6. While applying for power supply to the said MS Building/various buildings at the above address, all rules as per KERC ES&D Code shall be observed.
7. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCO at that time.
8. This 'NOC' is issued only for the purpose of obtaining sanction for the MS Building plan from BDA/BMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCO. Power supply will be sanctioned when applied for, subject to feasibility at that time.
9. The approximate load requirement of the above MS Building is **16 MW**.
10. The Validity of this NOC is for a period of Twelve Months only.

Yours faithfully,

**Chief Engineer Ele.,
(C,O&M), BMAZ, BESCO.**

Copy to:

1. The Superintending Engineer Ele., (C,O&M), Bangalore Circle North, BESCO, Bangalore.
2. The Executive Engineer, Ele., C,O&M, **Addl. Central Division**, BESCO, Bangalore.
3. The Asst. Executive Engineer, Ele., **C-7** Sub-Division, BESCO, Bangalore for information.



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

NO: CEE/BMAZ/SE(O)/AEE-2/F- 249/

Encl:

2794-97

Office Of

The Chief Engineer Ele.,
[C,O&M], BMAZ, No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

Date: 10/6/09

To,
M/s. Purvankara Constructions,
No. 130/1, Ulsoor Road,
Bangalore.

Sir,

Sub: Issue of NOC for arranging power supply to an extent of 16MW in Purvankara Constructions Sy. No. 30, 31, 32, 34 & 161 Kadathanamale Village, Doddaballapura Road, Bangalore.

- Reg:**
1. No. CEE(P&C)/KCO-95/8571/2008-09 dt: 06.05.09 45th TCCM Proceedings dt: 30.03.09 subject No. 22
 2. No. BESCOM/BC-47/GM(El.)/PP/F-3221(47)/08-09/451 dt: 01.06.09.
 3. T. O. Ltr. No. CEE/BMAZ/SE(O)/AEE-2/F-249/2561-64 dt: 06.06.09.
 4. Ltr. No. BESCOM/BC-47/GM(El)/PP/F-3221(47)/08-09/521 dt: 08.06.09.

In continuation to this office letter vide ref (3), the following corrections may be effected

As existing	As corrected
'No Objection Certificate' from BMAZ, BESCOM for the requisition load of 16 MW is hereby issued for the proposed Residencial Apartments in favour of M/s. Purvankara Constructions, at Sy. No. 30, 31, 32, 34 & 161 Kadathanamale Village, Doddaballapura Road, Bangalore at C-7 Sub-Division, Addl. Central Division	'No Objection Certificate' from BMAZ, BESCOM for the requisition load of 16 MW is hereby issued for the proposed Residencial Apartments in favour of M/s. Purvankara Constructions, at Sy. No. 30, 31, 32, 33 , 34 & 161 Kadathanamale Village, Doddaballapura Road, Bangalore at C-7 Sub-Division, Addl. Central Division

Other conditions remains unaltered.

Yours faithfully,

**Chief Engineer Ele.,
(C,O&M), BMAZ, BESCOM.**