

# PROVIDENT®

Ref: PHL/WWC/LTR/16-17/

Date: 04.01.2017

To

The DIRECTOR (TRANSMISSION),  
KPTCL, Kaveri Bhavan,  
Bangalore-9.

Dear Sir,

**Subject:** Usage of 66kV Covered Conductor with lesser clearance and Lower Right of Way for arranging Power supply in favor of Provident Housing Limited, Welworth City Project at Sy No: 30, 34 & 161 of kadathanamale Village, Doddaballapura Main Road, Bengaluru pertaining to C-7 sub-division of Hebbal Division- Reg

**Ref:** 1. Ltr No: 18/PHL/WWC/2015/Tech Dtd: 12.06.2015 of consumer.

2. Ltr No: CEE (P&C)/SEE (Plg)/KCO-95/E-26341/2010-11 Dtd: 25.04.2011.

3. BECOM/CGM (O)/DGM-OP3/AGM-OP1/BC-18/F-533(33)/15-16/3487-93

Dtd: 15.06.2015.

4. Ltr No: PHL/WWC/LTR/15-16/379 Dtd: 01.08.2015.

With reference to the above subject, and to the letters referred above, we wish to inform that we are ready to take up the 66kV line works under self-execution scheme. In this regard we have been advised to construct the 66kV line using covered conductor instead of bare conductor in order to solve the ROW issue for our project on hand "Provident Housing Limited, Wellworth City Project" where the power supply is to be given to the housing society at 66kV. The line has to move along from the 66kV KPTCL substation to the substation at the project site which is all along the Highway.

The length of this 66kV line is 2.8 circuit kms approximately and since this passes by the side of the road, the standard ROW of 18 meters for the bare conductors is not available. We propose to use the 66kV 99 sq. mm Covered Conductors on single concrete spun poles with triangular formation of the conductors, considering the available ROW and safety and the CEI notification in this regard.

Provident Housing Ltd.

No. 8, Ulsoor Road, Bengaluru - 560 042. Phone: 080 43428901, 43428999

Registered Office: 130/1, Ulsoor Road, Bengaluru - 560 042 Tel : 91-080-2559 9000/4343 9999 Fax : 91-080-2559 9350  
CIN: U45200KA2008PLC048273 E-mail: info@providenthousing.com www.providenthousing.com

*Cephus's letter*  
*Field in front of*  
*getting clearance from*  
*CEE for wiring (covered)*  
*Director (Transmission)*




This concept is already adopted and experienced by KPTCL for one of the project and based on that we are ready to adhere this same technology of using 66kV covered conductor on 11mts spun pole from the existing 11kV corridor as per the spot inspection & instructions given by Director Technical, KPTCL, during his visit to our site on 03.04.2015.

Thanking you,

Yours Faithfully,

For M/s Provident Housing Ltd.,

  
(PRASHANT MARATHÉ)

Authorized Signatory



Copy to: Chief Engineer, Electy. Transmission Zone,  
Ananda Rao Circle, Bangalore-560009

**Provident Housing Ltd.**

No. 8, Ulsoor Road, Bengaluru - 560 042. Phone: 080 43428901, 43428999

Registered Office: 130/1, Ulsoor Road, Bengaluru - 560 042 Tel : 81-080-2559 9000/4343 9999 Fax : 91-080-2559 931  
CIN: U45200KA2008PLC048273 E-mail: info@providenthousing.com www.providenthousing.com

Ref. 76/PHL/WWC/2022/TECH/54  
Date 07.11.2022

To,  
The Chief Engineer (Electy),  
Bengaluru Transmission Zone,  
KPTCL, Anandarao Circle,  
Bangalore.

Dear Sir,

**Subject** Requesting to Energize the KPTCL Station Executed in from M/s Puravankara Constructions, Provident Housing Ltd (Welworth City) at Sy No 30, 34&161, Kadathanamale village, Doddaballapura Main Road, Bangalore pertaining to C-7 sub division of Hebbal Division

- Ref. 1 BESCOM Power sanction letter CEE/BMAZ/SEE(O)/AEE-2/F151/3501-04  
Dtd. 04.07.2011
- 2 KPTCL CE,TRZ, Report No CEE/TZB/SEE(O)/AE-3/645/dt 14.11.2014
  - 3 CE, TZ, BLORE Letter No CEE/TZB/SEE(O)/AE-3/10696-703/dt:04.12.2014
  - 4 Reply letter to ref 4 to CE & D-Transmission. PHL No. nil dt 09.12.2014
  - 5 PWD Letter EE/PWD/BNG/DN/JE/2012-12 dt:04.08.2012
  - 6 PWD Letter EE/PWD-BNG/AE/2014-15/2657 dt 30.12.2014
  - 7 BESCOM corporate office Approval letter BESCOM/CGM(O)/DGM OP3/AGM-OP1/BC-18/F-533(33)/15-16/5345 Dated: 27.07.2015.
  - 8 KPTCL CE,TZ,KPTCL, BANGALORE Approval letter No CEE/TZB/SEE(O)/AE-3/645/14-15/ 3709-12 dt 22.06.2015
  - 9 KPTCL CE,TRZ, Corporate Approval to DGMT No CEE/TZB/SEE(O)/AEE-6/18-19/3866-70/dt 13 June 2018.
  - 11 BESCOM: EE/HD/AEE(EI)/AE-1/21-22/2799/dt 30.09.2021
  - 12 Our request letter 71/PHL/WWC/2021/ dated:03/11/2021.
  - 13 BESCOM corporate office Recommendation letter BESCOM/CGM(OP)/DGM-OP3/AGM-OP1/ BC-18/F-533(33)/21-22/9219-22 Dated: 22.02.2022
  - 14 BESCOM: AEE(EI)/C7/AE(T)/2022-23/2218-22/dt 23.08.2022
  - 15 Our request letter PHL/WWC/2021/TECH/45 dated:24/08/2022
  - 16 KPTCL CE,P&C, DCW Approval letter No. CEE/P&C/SEE(Plg)/EEE(IPP)/KCO-95/F-42304/2022-23/10645-49 dt 28.09.2022.

With reference to the above as per the direction from CE, P&C,Cauvery bhavan please arrange to collect the sanctioned OH lines and Transformer estimate cost under DCW

As per the BESCOM directions we have taken full sanctioned load of 16.83 MW service long back from 11KV Feeders and as per the conditions we have installed HT Metering cubicle with ETV meters to monitor the load consumed in the premises and ensure that our load should not exceed 7500KVA until today.

As per KPTCL sanctioned Approvals 66KV Overhead lines/3Cx300 Sqmm, AL, UG Cable, we can't execute the works along with Yealhanka - Doddaballapura Highway due to not getting permission.

**PROVIDENT HOUSING LIMITED**



from the authorities legal issues with PWD and NHAI, we are already to register the substation land along with infrastructure of 20 MVA 66/11KV substation in favor of KPTCL free of cost on 25<sup>th</sup> Nov 2015.

Due to idle stations equipment validity and performance has deteriorated and will not work desirably. Hence kindly take up the 66kv line works, as per the corporate approvals and BESCO Recommendations to KPTCL dually collecting already sanctioned overhead line/Transformer estimate cost from our end.

Under the above circumstances we have already left sufficient space for erection Two more power transformers and connected equipment's in our stations to cater surrounding area power requirements. We are ready to pay the necessary already sanctioned overhead line estimate cost under DCW.

Therefore, kindly request you to resolve the issue at the earliest, the necessary documents is here with enclosed for your kind reference.

Thanking you,

Yours faithfully,  
For Puravankara Constructions,  
(Represented by Provident Housing Limited)

Prashanth Marathe  
Authorized Signatory.





# KARNATAKA POWER TRANSMISSION CORPORATION LIMITED

Phone (Off) : 080-22350182  
Fax : 080-22350182  
E-Mail : eecebmwnd  
@ gmail com



Office of the  
Executive Engineer (Ele),  
Bangalore Major Works  
North Division,  
A.R. Circle, B'lore-09

No: EEE/BMWND/AEE (O)/F- /20011-12/

Dated: 17/09/2011

To

M/s Provident Housing Ltd.,  
130/1, Ulsoor Road,  
Bangalore 560042.

## WORK AWARD

Sir,

- Sub:** - Establishing 1X20 MVA, 66/11kV sub-station at M/s Provident Housing well worth city, Bangalore-Doddaballapura Road, Bangalore with associated line and Terminal Bay on self-execution basis.
- Ref:** - 1 Ltr No CEE (TR)/BZ/SEE (O)/AE-3/5946-47 dated 06/09/2011  
2. T O Ltr No: EEE/BMWND/AEE (O)/F-/2011-12/2712-14, dtd: 17/09/2011.  
3 Payment of Supervision Charges and Service charges vide T O Rt. No 019 dated 1.10.2011  
4 Your agreement dated -10.11.2011.

\*\*\*\*\*

The Chief Engineer Elec Transmission Bangalore Zone, in letter cited under reference (1) has sanctioned the following works

Sl. No	Name of the Work
1	Establishing 1X20 MVA, 66/11kV sub-station at M/s Provident Housing WELL WORTH CITY, Bangalore-Doddaballapura Road, Bangalore on self-execution basis
2	Construction of proposed 66kV SC line on DC towers using Drake ACSR from the existing 220/66kV Doddaballapura KIADB station to the proposed 1X20 MVA, 66/11kV sub-station at "WELL WORTH CITY" at Kadathanamale village, Doddaballapura Road, Bangalore on self-execution basis.
3	Construction of 66kV terminal bay at 220/66kV D.B.Pura KIADB station for the proposed 66kV SC line on DC towers from the existing 220/66kV Doddaballapura KIADB station to the proposed 1X20MVA, 66/11kV sub-station at 'WELL WORTH CITY' at Kadathanamale village, Doddaballapura Road, Bangalore on self-execution basis.

The 10% supervision charges of Rs 15 Lakhs and service tax of 1.54 Lakhs has been paid by you vide T O Rt No 019 dated 31.10.2011.

Design, manufacture, testing, supplying and commissioning of 66KV Station with associated line shall be carried out as per the detailed technical specifications of KPTCL.

Further the following procedure is to be followed before commencement of the work by the licensed electrical contractor

The list of firms from whom you intend to procure the material for carrying out the work shall got approved from Chief Engineer (Elec/Transmission Zone, KPTCL, A R Circle, Bangalore) and shall confirm to KPTCL specifications and approved drawings of KPTCL.

The above work has to be executed through Class I Licensed Electrical Contractor who is having the experience in similar work

#### **GENERAL CONDITIONS:**

The detailed specifications and drawings for each equipment shall be furnished to the Chief Engineer Elec, Transmission Zone, Bangalore for approval

All the equipments/materials are to be offered for inspection to KPTCL through the office of Chief Engineer Elec, Transmission Bangalore Zone before dispatch. The materials shall be used for the work only after inspection and issue of dispatch instructions from CEE (T).

The work shall be carried out under the supervision of Asst. Executive Engineer Elec/No 4 Sub-division of this division

The entire system constructed shall be got inspected and approved by the Chief Electrical Inspector, Govt. of Karnataka, before commissioning

The System constructed shall be guaranteed against any manufacturing defects for a period of 12 months from the date of commissioning & to that effect, an agreement shall be executed

All Instructions issued by this officer from the higher officer from time to time in connection with the above work shall be complied with. The works, which require shut down shall be got executed under shut down conditions only. However the shut down will be arranged at the discretion of KPTCL, and KPTCL will not be responsible for any delay in giving shut down for the work.

Dismantled items if any, shall be returned to the KPTCL Stores. The cost of Transportation shall be borne by you.

Any way-leave problem that may arise during the execution of the work will have to be sorted out by you at your cost.

You are solely responsible for any accident to the personnel engaged in the execution of work and no compensation is payable by KPTCL in this regards.

After completion of works, the entire work shall be handed over to KPTCL for maintenance purpose. The ownership of the lines and all the equipments rests with KPTCL.

The KPTCL reserves the right to direct the agency to replace the substandard material/equipment in the process of execution and also direct to redo the work with standard material/Equipments if situation warrants during / after execution.

(Ch. 19 M)  
Executive Engineer (E/E)  
Bangalore Major Works North Division,  
K P T C L, A R Circle, Blore - 09

APK/1

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED**

Office of the

Chief Engineer, Electricity,  
Planning & Co-ordination, KPITCL  
Kaveri Bhavan, 'A' Block,  
BENGALURU - 560 009



Phone : 91-080-22245056  
Fax : 91-080-22109521

E-mail : seetech.kpitcl@gmail.com

No. : CEE/P&C/SET/EE-12/AEE-7/KCO-109/34861/2017-18  
Encl.: 23399-402

Date : **7 MAR 2018**

To,  
**The Chief Engineer, Eley**  
**Transmission Zone,**  
**KPITCL, Bangalore**

Sir,

**Sub :** Arranging power supply in favour of M/s Provident Housing Ltd., at Sy. No 30, 34 & 161 of Kadahanamale village, Doddaballapura main road, Bengaluru- **Regarding 66kV UG cable**

**Ref:** 1. Y.O Note NO CEE/TZB/SEE(O)/AEE-6/17-18/18278 dated 08.03.2018  
2. Note approved by (D/T) KPITCL on 13/03/18.

Vide your office note cited under reference, it was requested for directions regarding providing 38/66kV, 3CX300sq mm, 3 phase UG cable for commissioning of the 66kV sub-station at M/s Provident Housing Kadahanamale Village, Doddaballapura office.

In this regard, I am directed to convey approval for providing "66kV, 3CX300sqmm, 3 phase cores of stranded compacted circular Aluminum Conductor screened with extruded semiconducting compound, TR XLPE insulated" for the subject work with a condition to provide spare jointing kits & cable length of 150Mtrs duly following other procedures as per corporate norms.

Yours faithfully,

  
Chief Engineer Electricity,  
Planning and Co-Ordination  
KPITCL, Bengaluru.



AEE-4  
20/3  
AEE-4  
20/3  
20/3

Copy to :

1. The Superintending Engineer, Tr(W), KPITCL, A.R.Circle, Bangalore-09
2. The Executive Engineer(E), BMWND, A.R.Circle, Bangalore-09
3. M/s Provident Housing Ltd, No 8, Ulsoor Road, Bengaluru-560042

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED**

Phone: 091 080 2212/3145  
 Fax: 091 080 2229/2204  
 Email Id: [cecpncc@gmail.com](mailto:cecpncc@gmail.com)



O/o Chief Engineer Electry,  
 Planning & Co-ordination  
 2<sup>nd</sup> Floor, Kaveri Bhavan,  
 Bengaluru- 560 009.

No. CEE (P & C)/SEE(Pig)/EEE(Pig-S)/KCO-95/F-100231/2018-19/

Date: 18 SEP 2018

The Chief Engineer Electry,  
 Bengaluru Transmission Zone,  
 KPTCL, Anandarao Circle,  
 Bengaluru-560009.



Sir

Slr	Subject:
1	Arranging power supply to an extent of 16.83 MW to the proposed M.S building of M/s. Puruvankara Constructions, at Kadathannamale village Doddaballapura Road, Bengaluru. Regarding laying of 38/66KV 3X300 Sq.mm. Al. UG Cable instead of OH line.
2	T O Letter No. (P & C)/KCO-95/F-8971/2008-09 Dated:06-05-2009 Proceedings of 45th TCC meeting held on 30-03-2009 Letter No. CEE/BMAZ/SE(O)/AEE-2/F-249/2561-64. Dated:06-06-2009
3	Letter No. BESSCOM/BC-47/GM (E)/F-2751/10-11/5281-84 datade- 30-03-2011 of GM. Operation, BESSCOM.
4	Letter No. CEE (TR)/SEE (O)/JEE-2/407. Dtd: 28-03-2011 of CEE. TZ Bangalore
5	T.O. Note No. CEE (P & C)/SEE (Pig)/KCO-95/26341/2010-11/Note-116 Dtd: 05-03-2011 approved by Director (Transmission), KPTCL on 16-04-2011.
6	T.O Letter No. No. CEE (P & C)/SEE(Pig)/KCO-95/F-26341/2010-11 Date:25-04-2011.
7	Letter No. PHL/WWC/2010-11/019 Dtd: 07-05-2011 of M/s. Provident Housing Limited
8	T.O Letter No. No. CEE (P&C)/SEET/KCO108/37715/PHL/11 12. Dtd: 20-05-2011.
9	T.O Letter No. No. CEE (P&C)/SEET/KCO109/34861/2017-18/27399-402/ Dtd: 17-03-2018.
10	T.O Letter No. No. CEE (P & C)/SEE (Pig)/KCO-95/F-64221/2018-19/R 62(BAN) Date:28-07-2018.
11	Letter No. CEE (TR)/SEE (O)/AEE 6/18-19/7327-31. Dtd: 07-08-2018 of CEE, TZ Bangalore
12	T.O letter No. CEE (P&C)/SEE(Pig)/EEE(Pig-S)/KCO-95/F-100227 / 2018 19/1/1949-58 dated 07-09-2018, Proceedings of 28th Power Sanction Committee meeting of Bengaluru Transmission Zone held on 18-08-2018

During the 28th Power Sanction Committee meeting of Bengaluru Transmission Zone held on 18-08-2018, the Committee approved /ratified the proposal of granting revised connectivity for arranging power supply to an extent of 16.83 MW to the proposed M.S

AE-1

CC to  
 10 marks to CE(M/S)

to mark  
 10 marks  
 20/8

20/8



building of M/s. Puruvankara Constructions, at Kadathanamale village Doddaballapura Road, Bengaluru with the following conditions.

i. M/s. Provident Housing Limited shall draw two runs of 66KV lines by laying 66KV 3X300 Sq.mm. Al. UG Cable between 220KV KIADB Dodda ballapura sub-station up to their proposed substation under self-execution

OR

ii. M/s. Provident Housing Limited shall draw one run of 66KV line by laying 66KV 3X300 Sq.mm. Al. UG Cable between 220KV KIADB Dodda ballapura sub-station up to their proposed substation (approved earlier) and shall have two 11KV feeders by drawing another 11KV line source with 11KV 3X400 Sq.mm. UG Cable between 220KV KIADB Dodda ballapura sub-station up to their proposed substation in addition to the existing 11KV OH line source for redundancy of power supply.


iii. M/s. Provident Housing Limited shall stand guarantee for life time maintenance of 66KV 3X300 Sq.mm. Al. UG Cable.

iv. CEE, BTZ, Bengaluru shall obtain an under taking for the above conditions in consultation with M/s. Provident Housing Limited for redundancy of power supply.

iii. Further other conditions mentioned in T.O. earlier approval remains unaltered.

**This is for information and further needful.**

Yours faithfully,

 17/9/18

**Chief Engineer Electy.,  
Planning & Co-ordination**

Copy for information to

- 1) The Chief General Manager (Ele), Operation, BESCO, Corporate Office, K.R. Circle, Bengaluru- 560001.
- 2) The Superintending Engineer Elec., Transmission (Works), KPTCL, Anandarao Circle, Bengaluru-560009
- 3) EA to DT, KPTCL for kind information of DT, KPTCL.
- 4) Copy to KCO-95

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED**

Phone: 091 080 22210416  
Fax: 091-080-22292204  
Email id: [ccepnc@gmail.com](mailto:ccepnc@gmail.com)



O/o Chief Engineer Electy.,  
Planning & Co-ordination  
4<sup>th</sup> Floor, Kaveri Bhavan,  
Bengaluru - 560 009.

No. No. CEE (P & C)/SEE(Plg)/EEE(IPP)/KCO-95/F-42304/2022-23/

10643-49

Date 28 SEP 2022

✓ The Provident Housing Limited.  
No.8, Ulsoor Road,  
Bengaluru-560009.

<b>Subject:</b>		Arranging power supply to an extent of 16.83 MW to the proposed M/S building of M/s Puruvankara Constructions, at Kadathanamale village Doddaballapura Road, Bengaluru- <b>Regarding taking 66KV UG Cable line work under DCW.</b>
<b>Ref</b>	1	T.O Letter No. (P & C)/ KCO-95/F-8971/2008-09 Dated:06/05/2009 Proceedings of 45th TCC meeting held on 30-03-2009
	2	T.O. letter No CEE (P&C)/SEE(Plg)/EEE(Plg S)/KCO-95/F-100227 / 2018-19/17949-58 dated 07.09.2018, Proceedings of 28th Power Sanction Committee meeting of Bengaluru Transmission Zone held on 18.08.2018
	3	T O letter No CEE (P&C)/SEE(Plg)/EEE(Plg S)/KCO-95/F-100231/2018 19/19865-67 dated 01.10.2018
	4	Letter No CGM(OP)/DGM(OP3)/AGM(OP1)/BC-18/f 533(33), 21.22/ 9219-22, dtd 22.02.2022 of CGM Elec., Operations
	5	M/s. Puruvankara Constructions letter No PHL/WWC/2021/TECH/45 dated 24-08-2022

Sir

During the 28th Power Sanction Committee meeting of Bengaluru Transmission Zone held on 18.08.2018, approval was accorded for the proposal of granting **revised** connectivity for arranging power supply to an extent of 16.83 MW to the proposed M.S. building of M/s. Puruvankara Constructions, at Kadathanamale village Doddaballapura Road, Bengaluru with the condition that applicant shall draw 66KV line by laying 66KV 3X300 Sq mm. Al. UG Cable between 220KV KIADB Dodda ballapura sub-station up to their proposed substation under self-execution.

Bi SCOM in their letter dated 22-02-2022 has reported that the consumer has given representation stating that they are unable to carry out the OH line work in the Highway due to not getting permission from PWD/NHA/ authorities.

Now, it is requested in your letter dated 24-08-2022 to take up the 66KV line work under DCW by KPTCL due to ROW issues.

In this regard, you are informed to approach the CEE, BTZ for preparation of estimate under DCW for the subject proposal. The approximate cost will be of Rs. 10.0 Crores for the work of laying 66KV 3X300 Sq.mm. Al. UG Cable between 220KV KIADB Dodda ballapura sub-station up to their proposed substation under DCW.

Further, you shall complete the proposed 66/11KV substation with installed capacity of 1X20MVA, 66/11KV power transformer at your premises in all aspects after replacing the faulty parts/equipments etc. under self-execution basis and 66kv line work will be commenced by KPTCL on DCW after reviewing the progress of 66/11kv sub-station.

Yours faithfully,

  
**Chief Engineer Electy.,  
Planning & Co-ordination**

Copy for information to

- 1) The Chief Engineer Electy. Bengaluru Transmission Zone, KPTCL, Anandarao Circle, Bengaluru-560009
- 2) The Chief General Manager (Ele), Operation, BESCOM, Corporate Office, K.R. Circle, Bengaluru- 560001.
- 3) The Superintending Engineer Elec., Transmission (Works), KPTCL, Anandarao Circle, Bengaluru-560009.
- 4) SPS to MD, KPTCL for kind information of MD, KPTCL.
- 5) EA to DT, KPTCL for kind information of DT, KPTCL.
- 6) Copy to KCO-95

ಕರ್ನಾಟಕ ವಿದ್ಯುತ್ ಪ್ರಸಾರಣ ನಿಗಮ ನಿಯಮಿತ

**KARNATAKA POWER TRANSMISSION CORPORATION LIMITED**

Corporate Identity Number (CIN) : U40109KA1999SGC025521

Ph No. : 080-22282601/602  
Fax No. : 080-22282846  
Email ID : ceemwbz@gmail.com



O/o Chief Engineer Electy.,  
Transmission Zone, KPTCL,  
A.R.Circle, Bengaluru-09


No: CEE/TZB/SEE(O)/AE-1/F-1480(324)/2022-23/  
Encl: Copy of letters.

Dated: 28 NOV 2022

1#062-64

To,

**The Superintending Engineer Elec.,**  
Transmission (Works) Circle,  
KPTCL, AR circle, Bengaluru.



Sir,

**Sub** : Arranging power supply to an extent of **16.83MW** to the proposed MS Building of **M/s.Purvankara Constructions** at Kadathanamale village, Doddaballapura Road, Bengaluru-**Regarding.**

- Ref** 1 Ltr No:(P&C)/KCO-95/F-8971/2008-09 dtd:06.05.2009 proceedings of 45<sup>th</sup> TCC meeting held on 30.03.2009.
- 2 Ltr No:CEE(P&C)/SEE(Plg)/EEE(Plg-S)/KCO-95/F-100227/2018-19/17949-58 dtd:07.09.2018 proceedings of 28<sup>th</sup> Power Sanction Committee meeting of Bengaluru Try Zone held on 18.08.2018.
- 3 Approval Ltr No:CEE(P&C)/SEE(Plg)/EEE(Plg-S)/KCO-95/F-100231/2018-19/18823-27 dtd:18.09.2018 of CEE(P&C).
- 4 Ltr No:CGM(OP)/DGM(OP-3)/AGM(OP-1)/BC-18/F-533(33)/21-22/9219-22 dtd:22.02.2022 of CGM Elec., OP BESCO addressed to CEE, P&C.
- 5 Ltr No:CEE(P&C)/SEE(Plg)/EEE(IPP)/KCO-95/F-42304/2022-23/10645-49 dtd:28.09.2022 addressed to M/s.provident Housing Ltd.,
- 6 Ltr No:76/PHL/WWC/2022/TECH/54 dtd:07.11.2022 of M/s.Provident Housing Limited.

\*\*\*\*\*

During the 28<sup>th</sup> Power sanction committee meeting of Bengaluru Transmission Zone held on 18.08.2018, approval was accorded for the proposal of granting revised connectivity for arranging power supply to an extent of 16.83MW to the proposed MS building of M/s.Purvankara

AE-4  
29/11




11 W  
A.L.L.  
Constructions at Kadathanamale village, Doddaballapura road, Bengaluru with the condition that applicant shall draw 66kV line by laying 66kV 3x300Sqmm AL UG cable between 220kV KIADB Doddaballapura sub-station upto their proposed sub-station under self execution.

Now based on the letter dtd:28.09.2022 of CEE, P&C, M/s.Provident Housing Limited vide letter dtd:07.11.2022 has requested to take up the work on DCW basis by KPTCL due to ROW issues (Copy of letters are enclosed).

In this regard, you are requested to inspect the spot and submit the detailed estimate under DCW for onward submission to GM (Tech) to communicate administrative approval.

Yours faithfully

  
Chief Engineer (Electy.)  
Transmission Zone Bengaluru

**Copy to:-**

1. The Executive Engineer Elecl., BMWND, KPTCL, AR Circle, Bengaluru.
2. M/s.Provident Housing Limited, 130/1, Ulsoor Road, Bangalore-560042
3. MF-OC/AE-1.